

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 125694
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38253

1 OWNER Air Force Civil Engineers ADDRESS AT WELL LOCATION Nellis Air Force Base
MAILING ADDRESS _____ Subdivision Name area # County Clark

2 LOCATION NW 1/4 SE 1/4 Sec 36 T 19 N R 62 E Latitude 36.253016 UTM E NAD 27
PERMIT/WAIVER NO. R-1724 Issued by Water Resources Parcel No. 123-36-000-001 Longitude -114.997478 N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NOI? _____
Is there an existing well log? Yes
If yes, what is NDWR well log #? 27093

4 EXISTING WELL CONSTRUCTION
Depth Drilled 1438 Feet Depth Cased 1432 Feet
EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>2.50</u>	<u>0</u>	<u>590</u>

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:
well was collapsed at 590'
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:
Type of perforation Factory Perf
Size of perforation 1/4"

From	feet to	feet	feet
	<u>288</u>	<u>590</u>	

If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: None

From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL
Static water level 116.8 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ ° F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From <u>0</u>	feet to <u>590</u>	feet <u>590</u>		<input checked="" type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
Well was collapsed at 590' pumped neat cement from bottom up took 24 yards

Neat Cement Fluid Weight lbs/gal 24.5cc mix
Bentonite Grout % bentonite neat cement
Date Started 7-28-16
Date Completed 7-28-16

DCNR/DWR/SNBO RECEIVED
JUL 28 2016

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Anzabon Pump Inc Contractor
Address 3632 N. 250 E. Contractor
Epoch UT 84721
Nevada contractor's license number issued by the State Contractor's Board 0073603A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2406
Signed _____
By driller performing actual drilling on-site or contractor
Date 7-28-16

USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 36.2530447
-114.996644