

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 125697
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38254
Nellis Air Force Base

1 OWNER Air Force Civil Engineers
MAILING ADDRESS _____

ADDRESS AT WELL LOCATION area II
Subdivision Name: _____ County Clark

2 LOCATION NW 1/4 NW 1/4 Sec 1 T 20 N R 62 E
PERMIT/WAIVER No. R-1726 1140-01-000-001
Issued by Water Resources Parcel No

Latitude 36.244392 UTM E NAD 27 NAD 83/WGS 84
Longitude -115.006268 N _____

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NOI? _____
Is there an existing well log? Yes
If yes, what is NDWR well log #? 2872

4 EXISTING WELL CONSTRUCTION
Depth Drilled 1247 Feet Depth Cased 1026 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: well had collapsed

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	39.3	.250	0	602
10	25.1	.250	602	789

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations

Existing Perforations:

Type of perforation	Size of perforation	From	To
<u>Factory</u>	<u>1 1/4"</u>	<u>100</u>	<u>14"</u>
		<u>602</u>	<u>feet</u>
		<u>602</u>	<u>10"</u>
		<u>789</u>	<u>feet</u>

Type of perforator used None

From	To	Number of perfs per linear foot
From	feet to	feet

5 WATER LEVEL
Static water level 86' feet below land surface
Artesian flow NO G.P.M. _____ P.S.I. _____
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	To	Material Used	Pumped	Poured
From <u>0</u>	feet to <u>789</u>	<u>789</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From	feet to		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to		<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
Pumped Neat Cement from Bottom up in 2 3/8" tremie pipe
well #3
took 29 Yards

Neat Cement Fluid Weight lbs/gal 24 sack mix
Bentonite Grout % bentonite neat cement
Date Started 7-26-16
Date Completed 7-26-16

DCNR/DWR/SNBO
RECEIVED
JUL 28 2016

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Anzalone Pumps Inc. Contractor
Address 3632 N. 250E Contractor
Enoch UT 84721
Nevada contractor's license number issued by the State Contractor's Board 0073603A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2406
Signed _____
By driller performing actual drilling on-site or contractor
Date 7-26-16

USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 36.2444207
-115.0054341 627A