

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 125698
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38255

1 OWNER Air Force Civil Engineers
MAILING ADDRESS _____

ADDRESS AT WELL LOCATION area #

2 LOCATION SW 1/4 SW 36 T 19 N R 62 E
PERMIT/WAIVER NO. R-1725 123-36-000-001
Issued by Water Resources Parcel No

Subdivision Name _____ County Clark
Latitude 36.249908 UTM E _____ NAD 27
Longitude -115.006226 N _____ NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? No
If yes, what is replacement well NOI? _____
Is there an existing well log? yes
If yes, what is NDWR well log #? 2873

4 EXISTING WELL CONSTRUCTION
Depth Drilled 1036 Feet Depth Cased 882 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:
well was collapsed at 686'

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14"</u>		<u>.250</u>	<u>0</u>	<u>603</u>
<u>10"</u>		<u>.250</u>	<u>603</u>	<u>686</u>

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations: None
Type of perforator used: None

From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot
From	feet to	feet	Number of perfs per linear foot

Existing Perforations:
Type of perforation Fracture
Size of perforation 1/4"

From	feet to	feet
From	feet to	feet

5 WATER LEVEL
Static water level 79.8 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From	feet to	feet	<u>686</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
pumped neat cement from bottom up

Neat Cement Fluid Weight _____ lbs/gal 24 sack mix
Bentonite Grout _____ % bentonite NEAT CEMENT
Date Started 7-27-16
Date Completed 7-27-16

well #4

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Anzalone Pumps Inc. Contractor
Address 3632 N. 250E. Contractor
Enoch, UT 84721
Nevada contractor's license number issued by the State Contractor's Board 0073603A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2406
Signed _____
By driller performing actual drilling on-site or contractor
Date 7-27-16

took 30 yards

DCN/RDWR/SNBO
RECEIVED
JUL 28 2016

USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 36.2499368
-115.0053919