STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125700
Permit No. 15702
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39005
WELL NAME *(if applicable)*: ABG

1. OWNER/CLIENT NAME William DeWitt
MAILING ADDRESS PO Box 1521
Southgate, Cal. 90280

DETAILED ADDRESS AT WELL LOCATION 751 N. Cascada Way
Amargosa Valley, Nv.
Subdivision Name: *County.* Nye

2. PLS LOCATION NE¼ SE ¼ 14 Sec 16 N 48 E
PERMIT/WAIVER NO. 15702 *Issued by Water Resources* 019-031-12 *Current Parcel No.*

Latitude 36.56154° UTM E ☐ NAD 27
Longitude 116.52566° UTM N ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log # 4379
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☑ Rotary ☐ RVC
☐ Air ☑ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
silt, sand			0	80	80
sandy clay			80	115	35
sand, fine gravel			115	190	75
clay			190	230	40
sand, gravel			230	270	40
silt, sand, gravel			270	290	20
sandy clay			290	380	90
silt, sand			380	465	85
clay			465	490	25
silt, sand			490	530	40

DCNR/DWR/SNBC
RECEIVED
JUL 22 2016

Date started: May 30, 20 16
Date completed: June 15, 20 16

7. WATER QUALITIES
Static water level: 124.7 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 68.4 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
700		6 hours

9. WELL CONSTRUCTION
Depth Drilled: 530 Feet Depth Cased: 530 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17½ Inches		0 Feet	530 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10¾	48	.365	+2	530

PERFORATIONS:
Type of perforation: Factory milled
Size of perforation: 3/16 x 2½
From 210 Feet To 530 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☐ Sanitary Seal to
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☑ Concrete Grout 0 to 55 ☐ Pumped ☑ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☑ Gravel Pack [> 0.2 in.] 55 to 530 ☐ Pumped ☑ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Nv. Webber Drilling *Contractor*
Address PO Box 40 Overton, Nv. 89040 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 0025887
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2238
Signed Bryan Anzalone *By driller performing actual drilling on site or contractor*
Date: July 15, 2016

(Rev. 08-12)
(NSPO Rev 11-12)
USE ADDITIONAL SHEETS IF NECESSARY
NAD 27 36.5615874 -116.5241076
(O) 627