

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125701
Permit No. _____
Basin No. _____

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34627
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME JL Investments, LLC DETAILED ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 1210 W. Ulrich Ct. 3200 W. Shelly Ln. Pahrump, NV 89048
Pahrump, NV 89060 Subdivision No. Charleston Park Ranchos Ut:6, Lot: _____ County: Nye

2. PLS LOCATION NE 1/4 NE 1/4 24 Sec 20-S N/5 52 E Latitude 36.204055° UTM E _____ NAD 27
PERMIT/WAIVER NO. _____ 28-771-34 Longitude -116.071257° UTM N _____ NAD 83 (N/GS 84)

Issued by Water Resources Current Parcel No. _____

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other _____

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Surface			0	4
Gray Clay & Granulated Caliche			4	17
Gray Clay			17	26
Brown Clay			26	68
Brown Clay & Caliche			68	96
Dark Brown Clay	X		96	125
Brown Clay & Caliche	X		125	150

9. WELL CONSTRUCTION

Depth Drilled: 150 Feet Depth Cased: 150 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>10</u> Inches	<u>0</u> Feet	<u>150</u> Feet	<u>150</u> Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.92</u>	<u>.28</u>	<u>0</u>	<u>150</u>
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Date started: 30-Jun 2016
Date completed: 01-July 2016

7. WATER QUALITIES

Static water level: 70 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 65 ° Fahrenheit
Water Quality: _____

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Baller <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

ANNULAR MATERIALS

Sanitary Seal Yes No

Neat Cement _____ to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout 0 to 50 Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Gravel Pack [> 0.2 in.] 50 to 150 Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

PERFORATIONS:

Type of perforation: Saw Cut
Size of perforation: 1/4" width 3" long

From 110 Feet To 150 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Jim Pike Well Drilling, LLC Contractor
Address P O Box 56 Pahrump, NV 89041 Contractor
Phone (775) 727-5435
Nevada contractor's license number as issued by the State Contractor's Board: 17563A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1324
Signed: Jim Pike
by driller performing actual drilling on site or contractor
Date: 07/05/16

NAD 27 36.2040946
-116.0703954