STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125708
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39111
WELL NAME (If applicable):

1. OWNER/CLIENT NAME: Courtney Walters
MAILING ADDRESS: 5375 Cameron St #M
Las Vegas NV 89118

DETAILED ADDRESS AT WELL LOCATION: Raven Ave & Cameron St.
Subdivision Name: County: Clark

2. PLS LOCATION: NE¼ NW¼ 19 Sec. 22 T. 61 S. E.
PERMIT/WAIVER NO. 177-19-102-012
Issued by Water Resources: Current Parcel No.

Latitude 36.025703° UTM E
Longitude -115.203588° UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Gravel w/ Streaks of Cement			0	310	
Gravel + Water			310	370	

DCNR/DWR/SNBO
RECEIVED
JUN 20 2016

Date started: 5-24-2016, 20
Date completed: 6-20-2016, 20

9. WELL CONSTRUCTION
Depth Drilled: 370 Feet Depth Cased: 370 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	50	Feet	370	Feet
12 1/4	Inches	0	Feet	50	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+2	50
6 1/2		.180 PVC	1 1/2	370

PERFORATIONS
Type of perforation: Factory
Size of perforation: 1/8 Save Type
From 310 Feet To 370 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☒ Sanitary Seal - 3/8 Lock Mix
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout 0 to 50 ☐ Pumped ☒ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 160 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Vernon H. Dimick (Contractor)
Address: 8005 W. Sahara Ave (Contractor)
Las Vegas NV 89148
Nevada contractor's license number as issued by the State Contractor's Board: 10062
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 552
Signed: V. H. Dimick (Driller performing actual drilling on site or contractor)
Date: 6-20-16

(Rev. 08-12)
(NSPO Rev 11-12)
USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 36.0257299 -115.2027579

(O) 627

01-27-2017 BY DSB