STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125709
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34624
WELL NAME (*if applicable*):

1. OWNER/CLIENT NAME MM Holdings LLC
MAILING ADDRESS 2941 Lorelei
Pahrump, NV 89048

DETAILED ADDRESS AT WELL LOCATION
3501 S. Mallard Ave.
Subdivision Name: C. V. Ut: 2, Blk: 33, Lot: 21 County: Nye

2. PLS LOCATION SE ¼ NE ¼ 36 Sec 20-S N/S 53 E
PERMIT/WAIVER NO. 41-064-01
Issued by Water Resources *Current Parcel No.*

Latitude 36.168124 UTM E ☐ NAD 27
Longitude -115.960684 UTM N ☒ NAD 83 WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Sandy Loam			0	27
Brown Clay & Caliche			27	70
Caliche			70	77
Brown Clay & Caliche			77	113
Brown Clay		X	113	170
Caliche		X	170	175
Brown Clay & Caliche		X	175	200

DCNR/DWR/SNBC
RECEIVED
JUN 27 2016

Date started: 16-Jun , 20 16
Date completed: 17-Jun , 20 16

9. WELL CONSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6/58	3.92	.28	0	200

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☒ Concrete Grout	0	to	50	☐ Pumped	☒ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50	to	200	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: Saw Cut
Size of perforation: 1/4" width 3" long

From	160	Feet	To 200	Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet

7. WATER QUALITIES
Static water level: 79 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 65 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Jim Pike Well Drilling, LLC
Contractor
Address P O Box 56 Pahrump, NV 89041
Contractor
Phone (775) 727-5435
Nevada contractor's license number as issued by the *State Contractor's Board:* 17563A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)* 1324
Signed: Jim Pike
By driller performing actual drilling on site or contractor
Date: 18-Jun, 2016

(Rev. 04-16) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

NAD27 36.1681618
-115.9598265