STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125710
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34626
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Richard D. Tankersley Renee A. Wiliam
MAILING ADDRESS 737 Airport Rd.
Monterey, CA 93940

DETAILED ADDRESS AT WELL LOCATION
3721 S. Prairie Ave. Pahrump, NV 89048
Subdivision Name: C.V. Ut: 4-A, Blk:23,Lot:7 County: Nye

2. PLS LOCATION NW ¼ SE ¼ 34 Sec 20-S N/S 53 E
PERMIT/WAIVER NO. 40-691-16
Issued by Water Resources *Current Parcel No.*

Latitude 36.165071° UTM E ☐ NAD 27
Longitude -116.003416° UTM N ☒ NAD 83 WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Surface			0	4
Brown Clay & Caliche			4	20
Caliche			20	27
Brown Clay			27	35
Caliche			35	41
Brown Clay			41	69
Brown Clay & Caliche		X	69	107
Brown Clay		X	107	150
Brown Clay & Caliche		X	150	200

DCNR/DWR/SNBO
RECEIVED
JUN 27 2016

Date started: 14-Jun 20 16
Date completed: 15-Jun 20 16

7. WATER QUALITIES
Static water level: 70 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 65 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6/58	3.92	.28	0	200

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout	0	to	50	☐ Pumped	☐ Poured
☒ Concrete Grout	0	to	50	☐ Pumped	☒ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50	to	200	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: Saw Cut
Size of perforation: 1/4" width 3" long

From	Feet	To	Feet
160	Feet	200	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Jim Pike Well Drilling, LLC
Contractor
Address P O Box 56 Pahrump, NV 89041
Contractor
Phone (775) 727-5435
Nevada contractor's license number as issued by the *State Contractor's Board:* 17563A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1324
Signed: Jim Pike
By driller performing actual drilling on site or contractor
Date: June 18, 2016

(Rev. 04-16) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

NAD 27 36.1651091
-116.0025574