

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125724
Permit No. _____
Basin No. _____

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38583
WELL NAME (If applicable): _____

1. OWNER/CLIENT NAME DANA LEBARON
MAILING ADDRESS 6990 CODITE RD.
LAS VEGAS NV 89178

DETAILED ADDRESS AT WELL LOCATION NW CORNER OF
WOODS AND PIMA ST. SANDY VALLEY NV.
Subdivision Name: _____ County: CLARK

2. PLS LOCATION SE 1/4 SE 1/4 23 Sec 24 N 56 E
PERMIT/WAIVER NO. 200-23-41-031
Issued by Water Resources Current Parcel No.

Latitude 35° 50' 19.83" N NAD 27
Longitude 115° 39' 46.47" W NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen. Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic ?
 Mining / Dewater
 Test / Other
 Irrigation Monitor
 Com / Ind Stock
 Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
SANDY LOAM			0	4	4
CLAY			4	28	24
CALICHE			28	34	6
CLAY			34	49	15
CALICHE			49	56	7
CLAY			56	66	10
CALICHE		TR-	66	75	9
CLAY			75	102	27
CALICHE		W.B	102	112	10
CLAY			112	128	16
CALICHE		W.B	128	140	12

9. WELL CONSTRUCTION
Depth Drilled: 140 Feet
Depth Cased: 140 Feet
HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 140 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188 STEEL</u>	<u>+2</u>	<u>8</u>
<u>4 1/2</u>	<u>2.36</u>	<u>.291 SDR 17</u>	<u>34</u>	<u>140</u>

PERFORATIONS:
Type of perforation: FACTORY SCREEN
Size of perforation: .032 INCH 4 ROW
From 100 Feet To 140 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

ANNULAR MATERIALS
 Sanitary Seal SURFACE to 50 FT.
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout SURFACE to 50 FT. Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Bentonite Grout _____ to _____ Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] _____ to _____ Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 6-6 20 2016
Date completed: 6-8 20 2016

7. WATER QUALITIES
Static water level: 6.5 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 63 ° Fahrenheit
Water Quality: _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name BUDGET Drilling LLC. Contractor
Address 1170 DARCY LN. PARRIPPA NV 8906 Contractor

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Baller <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Nevada contractor's license number as issued by the State Contractor's Board: 77029
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2160
Signed: Real [Signature]
Date: 7-12-2016