STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125726
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3733

1. OWNER MOISES VELASCO
MAILING ADDRESS 3018 SAN NICCOLO CT
N LAS VEGAS NV 89031

ADDRESS AT WELL LOCATION 5804 ROWLAND AVE
CLARK COUNTY
Subdivision Name: County: CLARK

2. LOCATION SW ¼ SW ¼ Sec 25 T 19S N/S R 60 E
PERMIT/WAIVER No. 125-25-410-022
Issued by Water Resources Parcel No.

Latitude N36°15'53.0" Longitude W115°13'20.7"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	5	-5
CALICHIE		5	40	-35
CLAY & CALICHIE		40	70	-30
LIGHT GREY CLAY		70	120	-50
DARK BROWN CLAY&GRAVEL		120	240	-120
RED SAND STONE & CLAY	WB	240	400	-160

DCNR/DWR/SNBO
RECEIVED
MAR 15 2016

Date started: 24-Feb , 20 16
Date completed: 2-Mar , 20 16

9. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12-1/4	Inches	0	Feet	55.3	Feet
7-7/8	Inches	55.3	Feet	400	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	+5	-55.3
4.5	2.794	.248	0	400

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 300 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☒ Concrete Grout	0 to 55.3		☐ Pumped	☒ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 0 to 400 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 101 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2513
Signed
By driller performing actual drilling on site or contractor
Date 3/9/2016

(Rev 05-05)
USE ADDITIONAL SHEETS IF NECESSARY

36.2047554
-115.2215777

09-02-2016 BY DSB