STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125789
Permit No.
Basin 093

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74479

1. OWNER: David Anderson
MAILING ADDRESS: 1395 Antelope Wy Rd, Reno Nv 89506
ADDRESS AT WELL LOCATION: 1206 Alum Rock Rd, Reno Nv 89506
Subdivision Name:
County: Washoe

2. LOCATION: NE NW Sec. 14 T. 22 N R. 19 E
PERMIT/WAIVER No.
Latitude
Longitude
UTM E 0258389 ☒ NAD 27
N 4407201 ☐ NAD 83/WGS 84
Project No. 079-500-61

3. WORKED PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brwn Sand & Clays		0	25	25
Brwn Clays		25	60	35
MC Sand & Gravel		60	68	8
Brwn Clay & Grey clay		68	100	32
MC Sand & Gravel	X	100	110	10
Brwn clay w/ Sand & Gravel Stringers	X	110	300	190

NAD 27
39.782368°N
119.821285°W

RECEIVED 2016 MAY 17 AM 10:19 STATE ENGINEER'S OFFICE

Date Started: 5-9-16 20
Date Completed: 5-12-16 20

7. Water Level
Static water level: 104 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		4 hrs

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	300

Perforations
Type of perforation: factory
Size of perforation: .06
From 140 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 60 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 60 to 300 ☐ Pumped ☒ Poured
Type: 3/8 Rock
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: Welsco Corporation (Contractor)
Address: P.O. Box 888 (Contractor)
Fallon, Nevada 89407
Nevada contractor's license number issued by the State Contractors Board: 0011752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1727
Signed: David Anderson
By driller performing actual drilling on-site or contractor
Date: 5-16-16

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627