STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125790
Permit No. 33050
Basin No. 091

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 73212
WELL NAME (if applicable):

1. OWNER/CLIENT NAME M.L. Belli
MAILING ADDRESS 2450 Warrior Lane
Reno, NV 89523

DETAILED ADDRESS AT WELL LOCATION Warrior Lane
Reno, NV 89523
Subdivision Name Belli Ranch Estates County Washoe

2. PLS LOCATION NW ¼ SW ¼ 15 Sec 19 N/S 18 E
PERMIT/WAIVER NO. 33050 (Issued by Water Resources) 038-560-17 (Current Parcel No)

Latitude 39.50878 UTM E ☐ NAD 27
Longitude -119.95433 UTM N ■ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ■ Deepen: Orig WL# Unknown
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ■ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ■ Rotary ☐ RVC
☐ Air ■ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Grey Rock & Gravel			390	440
Grey Rock & Gravel			440	450
Dark Brown Clay & Rock			450	460
Grey Rock & Grey Clay			460	502
T.D. 502'				
NAD 27				
39.508870°N				
119.953298°W				

Date started: 13-May, 20 16
Date completed 18-May, 20 16

7. WATER QUALITIES
Static water level: 140 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air Lift	20		2.5 Hours

9. INSTRUCTION
Depth Drilled: 502 Feet Depth Cased: 502 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	390	Feet	502	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.72	0.188	280	502

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

PERFORATIONS:
Type of perforation: Factory Sawed
Size of perforation: 3/32 x 3
From 442 Feet To 482 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name A.S.A.P.Pump & Well Service,LLC. (Contractor)
Address P.O. Box 60130 Reno, Nevada 89506 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board 35387C
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller) 2382
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5/19/2016

(Rev. 12-13)
USE ADDITIONAL SHEETS IF NECESSARY
pg. 1 of pg. 1

Deepens Unknown Well log