STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125806
Permit No.
Basin No. 087

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 75677
WELL NAME (If applicable): DW#259

1. OWNER/CLIENT NAME: Reno City of c/o Property Management
MAILING ADDRESS: P.O. BOX 1900, Reno, NV 89505

DETAILED ADDRESS AT WELL LOCATION: 0 Pembroke Drive, Reno, NV
Subdivision Name:
County: Washoe

2. PLS LOCATION: NW ¼ SE ¼ 22 Sec 19N N/S 20 E
PERMIT/WAIVER NO.: DW-145 (Issued by Water Resources) 021-160-45 (Current Parcel No.)

Latitude: 39.498078° Longitude: -119.724322
UTM E: UTM N:
☐ NAD 27 ■ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
■ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / GM ☐ Rec

5. WELL TYPE
■ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Silty Clay & Rock			0	7
Silty Sand			7	14
Silty Clay			14	16
Sand			16	20
Plugged by Well log 123090				

Date started: 12-Jul, 20 16
Date completed: 12-Jul, 20 16

7. WATER QUALITIES
Static water level: 7 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
	NAD 27	
	39.498166	
	119.723301	

9. WELL CONSTRUCTION
Depth Drilled: 20 Feet Depth Cased: 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	SCH 40	0	20

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
■ Bentonite Chips	5	to	8	☐ Pumped	■ Poured
■ Gravel Pack [> 0.2 in.]	0	to	20	☐ Pumped	■ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: Machine Slot
Size of perforation: 0.032

From	Feet	To	Feet
0	Feet	20	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name: Viking Drillers, Inc. (Contractor)
Address: 5950 Granite Lake Drive, Granite Bay, CA 95746 (Contractor)
Phone: 916-742-1500
Nevada contractor's license number as issued by the State Contractor's Board: 0034680
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2361

Signed: (By driller performing actual drilling on site or contractor)
Date: 08-01-16

(Rev. 04-14) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.