STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125822
Permit No.
Basin No. 049

NOTICE OF INTENT NO. 72782
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Shane Fellow
MAILING ADDRESS 295 MVR #12
Elko, NV 89801

DETAILED ADDRESS AT WELL LOCATION 4656 Shield St.
Elko, NV 89801
Subdivision Name: MVR#4 County: Elko

2. PLS LOCATION SW ¼ NE ¼ 19 Sec 35 N/S 56 E
PERMIT/WAIVER NO. 036.[redacted]-015-001
Issued by Water Resources Current Parcel No.

Latitude 40.906.981 UTM E
Longitude 115.706.781 UTM N
NAD 27 ☐ NAD 83/WGS 84 ☒

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Top Soil			0	2
Hard Pan			2	8
Clay			8	12
Silt Stone			12	160
Silt Stone & Gravel			160	175
Water Strata		X	175	180
Silt Stone & Gravel			180	200
Water Strata		X	205	
Silt Stone & Gravel			200	210
Water Strata		X	220	
Silt Stone & Gravel mix			215	230

Date started: 27-Jul , 20 16
Date completed: 3-Aug , 20 16

7. WATER QUALITIES
Static water level: 130 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 62 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
35		3
	NAD 27	
	40.907041	
	115.705880	

9. WELL CONSTRUCTION
Depth Drilled: 230 Feet Depth Cased: 230 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	230 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	+2	30
6 5/8		SR	30	230

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement	55 to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	55 to	230	☐ Pumped	☐ Poured
Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Mill slot
Size of perforation: 0

From	To
220 Feet	230 Feet
Feet	Feet
Feet	Feet
Feet	Feet
Feet	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Fertig Drilling Company (Contractor)
Address 422 Elko Summit #2 (Contractor)
Phone 775 753 7960
Nevada contractor's license number as issued by the State Contractor's Board: 031904
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1489
Signed: (Driller performing actual drilling on site or contractor)
Date: 8-24-16

(Rev. 04-16)
USE ADDITIONAL SHEETS IF NECESSARY
pg. of pg.