STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125831
Permit No
Basin No 088

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety
accordance with NRS 534.170 and NAC 534.170

NOTICE OF INTENT NO 73209
WELL NAME (if applicable)

1. OWNER/CLIENT NAME: Alan Cabito
MAILING ADDRESS: 930 Tahoe Blvd #802-341
Incline Village, NV 89451

DRILLING ACTIVITY/WELL LOCATION: 16130 Mt. Rose Hwy
Reno, NV 89511
County: Washoe

2. PLS LOCATION: NE ¼ SE ¼ 34 Sec 18 Nev 19
PERMIT/WATER NO: 049-070-28
Latitude: 39.37944 Longitude: 119.83
☐ NAD 27 ■ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig Wt #
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ■ Rotary ☐ RVC
☐ Air ■ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Last Cut	Water Strike	From	To
Dirt			0	5
Grey & White Granite			5	10
Sand & Gravel			10	30
Multi-Colored Rock & Sand			30	400
Multi-Colored Rock			400	560
Multi-Colored Rock & Brown Clay			560	580
Multi-Colored Rock			580	620
Multi-Colored Rock & Brown Clay			620	640
Muti-Colored Rock, Red Clay, Sand			640	660
Muti-Colored Rock			660	696
T.D. 696'				

Date Started: 25-Apr, 20 16
Date Completed: 11-May, 20 16

RECEIVED 2016 MAY 23 AM 10:16 LAND ENGINEERING OFFICE

7. WATER QUALITIES
Static water level: 480 Feet below land surface
Artesian Flow: G.P.M P.S.I.
Water Temperature: 70 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air Lift	20+		4 Hours

9. INSTRUCTION
Depth Drilled: 696 Feet Depth Cased: 696 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	55	Feet
8 1/2	Inches	55	Feet	696	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	0.188	+2	696

ANNULAR MATERIALS

Sanitary Seal ■ Yes ☐ No

■ Neat Cement	0	to 50	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
■ Gravel Pack [> 0.2 in]	50	to 696	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS

Type of perforation: Factory
Size of perforation: 3/32 x 3

From		To	
596	Feet	636	Feet
656	Feet	696	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name: A S A P Pump & Well Service,LLC
Contractor

Address: P.O. Box 60130 Reno, Nevada 89506
Contractor

Nevada contractor's license number as issued by the: 35387C
Nevada well driller's license number as issued by the: 2362

Larry Welch
5/12/2016

(Rev 12-13)

USE ADDITIONAL SHEETS IF NECESSARY

pg. 1 of pg. 1

NAD 27: 39.379530°N
119.828978°W