STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125844
Permit No.
Basin No. 084

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73852
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Advanced Investments
MAILING ADDRESS 955 Deming Way Sparks NV 89431
DETAILED ADDRESS AT WELL LOCATION 100 Wrangler
Subdivision Name: County: Washoe

2. PLS LOCATION SW ¼ NW ¼ 15 Sec 22 N/S 21 E
PERMIT/WAIVER NO. 072.510.10 *Issued by Water Resources* *Current Parcel No.*
Latitude 39.776490 UTM E ☐ NAD 27
Longitude 119.62023 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Powder clay			0	4	4
Sand & Gravel			4	73	69
Chip Rock			73	85	12
Gravel			85	115	30
Clay			115	123	8
Sand			123	167	44
Sand & Gravel			167	235	68
Med to Large			235	/	
Gravel			/	350	115

Date started: 8-8-16, 20
Date completed: 8-10-16, 20

9. WELL CONSTRUCTION
Depth Drilled: 350 Feet Depth Cased: 350 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	350	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+3	350

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 1/16
From 250 Feet To ~~280~~ 270 Feet
From ~~300~~ 290 Feet To ~~320~~ 310 Feet
From 330 Feet To 350 Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0 to 62			
☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	0 to 62		☐ Pumped	☒ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☐ Bentonite Grout	to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	62 to 350		☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 112 Feet below land surface
Artesian Flow: NO G.P.M. 25-30 P.S.I.
Water Temperature: 66 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
250'	25-30	NAD 27	3 hrs
		39.776491	
		119.619685	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC. *Contractor*
Address P.O. Box 1255 Carson City, NV 89702 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 46499A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2321
Signed: C. Robinson *By driller performing actual drilling on site or contractor*
Date: 8-26-16

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY
(NSPO Rev 11-12) (O) 627