

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125948
Permit No. _____
Basin No. 089

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73324
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME EUERKA BUILDERS
MAILING ADDRESS 1770 DORI WAY SUITE A
CARSON CITY, NV 89706

DETAILED ADDRESS AT WELL LOCATION 3020 KAUFFMANN
WASHOE CITY, NV 89706

2. PLS LOCATION SW ¼ NE ¼ 5 Sec 16 N/S 20 E
PERMIT/WAIVER NO. _____
050-550-15
Issued by Water Resources Current Parcel No.

Subdivision Name: _____ County: Washoe
Latitude 39.282955*N UTM E NAD 27
Longitude 119.760034*W UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Corn / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
DG SANDS			3	58
HARD DG GRANITE			58	125
BLUE GRANITE			125	240
SMALL FRACTURES				
FRACTURED GRANITE		XXX	240	300

9. WELL CONSTRUCTION
Depth Drilled: 300 Feet Depth Cased: 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0	120
9 7/8 Inches	120	240
6 Inches	240	300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8 sdr 21	4.26	.216	20	240
5	4.06	.216	240	300

ANNULAR MATERIALS
Sanitary Seal x Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout 0 to 60 Pumped Poured
 Concrete Grout to _____ Pumped Poured
 Bentonite Chips to _____ Pumped Poured
 Gravel Pack [> 0.2 in.] to _____ Pumped Poured
 Sand Pack [< 0.2 in.] to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 18-Apr 20 16
Date completed: 26-Apr 20 16

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: 3 X 3/32
From 200 Feet To 240 Feet
From 260 Feet To 300 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

7. WATER QUALITIES
Static water level: 75 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 48° ° Fahrenheit
Water Quality: GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Baller <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>75</u>	<u>3 HOURS</u>

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC
Contractor
Address 20 KIT KAT DRIVE WASHOE VALLEY, NV 89704
Contractor
Phone _____
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905
Signed: Michael J. Dack
by driller performing actual drilling on site
Date: 4/25/2015