STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125855
Permit No.
Basin No. 044

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73743
WELL NAME (If applicable): OMW-17R

1. OWNER/CLIENT NAME JERRITT CANYON GOLD LLC
MAILING ADDRESS HC-31 BOX 78 ELKO, NV 89801

DETAILED ADDRESS AT WELL LOCATION JERRITT CANYON MINE
Subdivision Name: County: ELKO

2. PLS LOCATION NW ¼ SE ¼ 33 Sec 41N N/S 54 E
PERMIT/WAIVER NO. MO-2060 (Issued by Water Resources) (Current Parcel No.)

Latitude 41 24'33.28" UTM E
Longitude 115 54'13.16" UTM N
☐ NAD 27 ■ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
■ Replacement: Original well log # ?
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ■ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ■ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
ALLUVIUM,CLAYSAND, GRAVEL			0	120
NAD27				
41.409333°N				
115.902721°W				

Date started: 5-5-16 , 20 16
Date completed 5-5-16 , 20 16

9. CONSTRUCTION
Depth Drilled: 120 Feet Depth Cased: 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.5	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		SCH. 40	0	120

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

■ Neat Cement	20	to 0	■ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
■ Gravel Pack [> 0.2 in.]	38	to 120	☐ Pumped	■ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: MACHINE
Size of perforation: .020

From 40	Feet	To 120	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

7. WATER QUALITIES
Static water level: 73.5' Feet below land surface
Artesian Flow: 0 G.P.M. P.S.I.
Water Temperature: N/A ° Fahrenheit
Water Quality: N/A

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear Company (Contractor)
Address PO Box 2748 Elko, NV. 89803 (Contractor)

Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1395
Signed: (By driller performing actual drilling on site or contractor)
Date: 05/16/16

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replaces Unknown Well log