STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125869
Permit No.
Basin No 049

NOTICE OF INTENT NO. 72770
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Juan & Ashley Meza
MAILING ADDRESS 2616 Copper Trail
Elko, NV 89801

DETAILED ADDRESS AT WELL LOCATION 2550 Florida
Subdivision Name
County: Elko

2. PLS LOCATION NW ¼ NW ¼ 7 Sec 34 N/S 56 E
PERMIT/WAIVER NO. 032 006 016
Issued by Water Resources Current Parcel No

Latitude 40'51.156N UTM E ☐ NAD 27
Longitude 114'43.125W UTM N X NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement. Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	3
Sand & gravel			3	8
Siltstone			8	25
Gravel & Sand			25	30
Blue Clay			30	180
Sand & gravel		X	180	190
Blue Clay			190	225
Gravel		X	225	227
Blue Clay			227	240
Gravel		X	240	245

NAD27
40.852679°N
115.717850°W

Date started: April 4, 20 2016
Date completed: 6-Apr 20 2016

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 52 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
60		2

9. INSTRUCTION
Depth Drilled: 245 Feet Depth Cased: 245 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8 Inches		0 Feet	245 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	+2	25
6 5/8		SP17	25	245

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	5	to 30	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips	30	to 105	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]	105	to 245	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: mill slot
Size of perforation: 0.1
From 225 Feet To 245 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Fertig Drilling (Contractor)
Address 422 Elko Summit #2 Elko, NV 89801 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board.* 031904
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)* 1689
Signed: (Driller performing actual drilling on-site or contractor)
Date: 4-18-16

(Rev 12-13)
USE ADDITIONAL SHEETS IF NECESSARY
pg. of pg.