STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125880
Permit No.
Basin No. 173B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39002
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Jenkins Farms
MAILING ADDRESS 3365 La Mesa rd
SLC ut. 84109

DETAILED ADDRESS AT WELL LOCATION 1250 N. Jenkins Lane
Nyala Nv.
Subdivision Name: *County:* Nye

2. PLS LOCATION SE ¼ NW ¼ 34 Sec 50 S 55 E
PERMIT/WAIVER NO. B4245 *Issued by Water Resources* *Current Parcel No.*

Latitude 38° 15.091 UTM E ☑ NAD 27
Longitude 115° 46.831 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☑ Rotary ☐ RVC
☐ Air ☑ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
silt, sand, clay			0	75	
sandy clay			75	130	
sand, fine gravel			130	185	
clay			185	200	
sand, gravel			200	260	
sand, clay			260	340	
sand			340	370	
clay			370	400	
NAD 27					

Date started Nov. 1 , 20 15
Date completed: Dec 15 , 20 15

7. WATER QUALITIES
Static water level: 124.6 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 52.3 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air lift	600		8 hrs
Test pump	1600	152.6'	40 hrs

9. WELL CONSTRUCTION
Depth Drilled: 400 Feet Depth Cased: 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
25	Inches	0	Feet	400	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	62.3	.375	0	400

PERFORATIONS:
Type of perforation: Factory milled
Size of perforation: 3/16 x 2 1/2
From 160 Feet To 400 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to		
☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout	0	to 60	☐ Pumped	☑ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]	60	to 40	☐ Pumped	☑ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Nv. Webber Drilling *Contractor*
Address PO Box 40 Overton, Nv. 89040 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 0025887
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2238
Signed: Bryan Anzalone *By driller performing actual drilling on site or contractor*
Date: June 9 2016

(Rev 08-12)
(NSPO Rev 11-12)
USE ADDITIONAL SHEETS IF NECESSARY
(O) 627