

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY

Log No. 13216

Permit No. 27874

Basin Walker Lake V

1. OWNER Delbert K. Cornella ADDRESS 109 English Street  
Hawthorne, Nevada

2. LOCATION SE 1/4 NE 1/4 Sec. 8 T. 9 N/S R. 29 E Mineral County

PERMIT NO. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine to coarse sand w/ rounded cobbles to 8" diameter. Formation very clean & loose- hard		0	25	25
Coarse sand w/ semi- rounded gravels to 5" diameter - very clean		25	85	60
Fine to coarse sand w/ broken, angular gravels to 4" diam.- formation absorbs air. Water bearing		85	150	65
<i>plugged by well log 119733</i>				
<i>replaced by log 119732</i>				

8. WELL CONSTRUCTION  
 Diameter hole 6 inches Total depth 145 feet  
 Casing record 0-145' X 6 5/8" ID  
 Weight per foot 12.82 Thickness 188

Diameter	From	To
10 inches	0	55
8 inches	55	150
_____ inches	_____	_____

Surface seal: Yes  No  Type neat cement  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation factory mill slots  
 Size perforation 1/8 X 2 3/8  
 From 105 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 105 Feet below land surface  
 Flow (.56) G.P.M.  
 Water temperature cold ° F. Quality not tested

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W.L. McDonald & Co.  
 Address 1955 18th Street; Sparks, Nev.  
 Nevada contractor's license number 9767  
 Nevada driller's license number 493  
 Signed [Signature]  
 Date 6-5-73

Date started 5-23-73, 19\_\_\_\_  
 Date completed 5-30-73, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN & TEST PUMPED:			
20-25GPM @ 140' depth			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____