DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 14022
Permit No. 27571
Basin Eagle Valley

1. OWNER Lakeview-Franktown Washoe ~~xxxxxx~~ Valley Water Company
ADDRESS P.O. Box 1847, Carson City, Nevada

2. LOCATION NE ¼ SW ¼ Sec. 1 T. 15 N/S R. 19 E County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Wet Clay		0	6	
Hard & Soft DG, with clay....		6	25	
Soft DG		25	40	
DG, soft		40	57	
DG with clay streaks, medium soft.....		57	72	
Gray & brown DG, medium hard, clay streaks with moisture evident.....		72	87	
Soft brown DG with clay.....		87	102	
Soft brown DG, water bearing.....		102	117	
Hard gray DG, fractured		117	132	
Fractured dark granite partially decomposed		132	147	
DG, gray & brown, water bearing.....		147	162	
DG, soft with clay, water evident.....		162	177	
Hard granite		177	179	

Date started May 4, 19 74
Date completed May 13, 19 74

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	25	75'	6½

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole ..... inches Total depth 177 feet
~~Casing record~~ 0 to 50', 16", 50 to
~~Weight per foot~~ 179, 12" Thickness 188W

Diameter		From		To	
8	inches	0	feet	170	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Factory
Size perforation 1/8 X 3
From 90 feet to 170 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 70 Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Burroughs of Nevada
Address 10310 Old Virginia City Road
Reno, Nevada
Nevada contractor's license number 5092
Nevada driller's license number 751
Signed [signature] May 15, 1974
Date

USE ADDITIONAL SHEETS IF NECESSARY

5471