DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 14261
Permit No.
Basin ✓

1. OWNER Bill Alexander ADDRESS 289 Fir St Elko, Nev 89801

2. LOCATION E ½ ¼ Sec. 13 T. 33 N/S R. 57 E. Elko County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Clay, gravel | | 0 | 65 | 65 |
| Sand (Caving) | x | 65 | 135 | 70 |
| Brown Clay | | 135 | 140 | 5 |

Date started 6-24, 1974
Date completed 7-8, 1974

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 20 Draw down 0 feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. 0-55 - 12" WELL CONSTRUCTION
Diameter hole 55-140 - 8 inches Total depth 140 feet
Casing record
Weight per foot Thickness .188

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 140 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 0-55 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory Cut
Size perforation ⅛ x 3
From 100 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60 Feet below land surface
Flow G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name O M Gullard Drilling Co
Address P O Box 41 - Elko, Nev 89801
Nevada contractor's license number 4796
Nevada driller's license number 115
Signed O M Gullard
Date 7-8-74

USE ADDITIONAL SHEETS IF NECESSARY

5471