

Log No. 1A328
 Permit No. 28356
 Basin Tahoe Segment 9

WELL DRILLERS REPORT

Please complete this form in its entirety

Well #3 flowing

1. OWNER Carlsberg Development, Inc. ADDRESS Reno, Nevada
(Lake Tahoe Recreational Land Co.)

2. LOCATION SW 1/4 SW 1/4 Sec. 36 T. 18N N/S R. 21 E Storey County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dark brown clay topsoil		0	1	1
Clay w/ angular gravels to 1 1/2"		1	24	23
Blue to grey to green clay w/ yellow lenses		24	38	14
Hard dry yellow clay		38	40	2
Brown sandy clay w/ coarse sand & 1/2" angular gravels		40	63	23
Broken formation w/ 70% clay mixed		63	97	34
Yellowish brown clay w/ 3/8" angular gravels		97	125	28
Grey claylike material				
10GPM @ 130' depth		125	134	9
Red to pink broken rock		134	138	4

8. WELL CONSTRUCTION
 Diameter hole 8 3/8 (50-138) inches Total depth 138 feet
 Casing record _____
 Weight per foot 12.82 Thickness .188

Diameter	From	To
<u>6.5/80D</u> inches	<u>0</u> feet	<u>138</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type transit mix
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation oxy-acet. torch
 Size perforation 3/16 x 5"
 From 118 feet to 138 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ Feet below land surface
 Flow 135 G.P.M. G.P.M.
 Water temperature 72 °F. Quality not tested

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
 Address P.O. Box 404; Sparks, Nevada
 Nevada contractor's license number 9767
 Nevada driller's license number 685
 Signed Michael O. Shae by W.L.M.
 Date 9-9-74

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Flowing @ 135 G.P.M. plus

BAILER TEST

G.P.M.	Draw down	feet	hours