

OFFICE USE ONLY
 Log No. 14859
 Permit No. 29183
 Basin.....

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER MILTON KAY ADDRESS 769 E. 4070 S.
HILLTOP RD. SALT LAKE CITY, UTAH
BATTLE MTN, NV
 2. LOCATION NW 1/4 SW 1/4 Sec. 2 T. 31 N/S R. 45 E. LANDER County
 PERMIT NO.....

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SOIL (clay)		0	10	10
SAND, GRAVEL, CLAY	✓✓	10	60	50
SANDY CLAY		60	132	72
SAND & GRAVEL	✓✓✓	132	142	10
BLUE CLAY		142	145	3
T.D.		145		

8. WELL CONSTRUCTION
 Diameter hole 12 1/4 inches Total depth 145 feet
 Casing record 146'
 Weight per foot 16.94 Thickness 1.98

Diameter	From	To
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

 Surface seal: Yes No Type PORTLAND CEMENT
 Depth of seal 5.4 feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet
 Perforations:
 Type perforation MILL SLOTS
 Size perforation 1/8" x 3"
 From 10.3 feet to 145 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started..... 6/25 1975
 Date completed..... 6/30 1975

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 1.2 Feet below land surface
 Flow..... G.P.M.
 Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CURT WEAVER Muth Drilling Co.
203 Pine Street
 Address..... Elko, Nevada 89801
 Nevada contractor's license number 10819
 Nevada driller's license number 670
 Signed James Y. Muth (632)
 Date 7/7/75

BAILER TEST
 G.P.M. 3.0 Draw down 3.5 feet 2 hours
 G.P.M. Draw down..... feet hours
 G.P.M. Draw down..... feet hours