

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER John Royce Construction ADDRESS 15505 Callahan Ranch Road
Reno, Nevada

APN 045-542-05

2. LOCATION $\frac{1}{4}$ 2 $\frac{1}{4}$ Sec. 17N T. 19 N/S R. E WASHOE County
 PERMIT NO. 5500 Tannerwood Dr. Job #146; GALINA TERRACE ESTATES #1; Lot 51

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil, brown clay & boulders		0	8	8
Gray decomposed granit sand & boulders w/ clay		8	18	10
Brown decomposed granit sand & clay w/ boulders		18	69	51
Brown clay & decomposed granit sand med.		69	150	81
Loose brown decomposed granit sand & decomposed granit sand gray				
water bearing		150	200	50

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 200 feet
 Casing record 0-200 x 6 5/8
 Weight per foot 12.89 Thickness .188

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 1/2</u> inches	<u>50</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type transit mix
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation factory mill slot
 Size perforation 1/8 x 2 1/2
 From 179 feet to 200 feet
 From _____ feet to _____ feet

Date started 3-23-77, 19_____
 Date completed 3-23-77, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN	8GPM @	175' depth	
	13GPM @	195' depth	

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 160 Feet below land surface
 Flow _____ G.P.M.
 Water temperature cold ° F. Quality not tested

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W.L. McDonald & Co.
 Address P.O. Box 404; Sparks, Nv. 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 805
 Signed Tony Betita by W.L. McDonald
 Date 7 April 1977