

WELL DRILLERS REPORT

Please complete this form in its entirety.

1. OWNER Silver State Construction ADDRESS 470 Savarian Dr. Carson City, Nev.

2. LOCATION SE 1/4 1/4 Sec. 14 T. 14N N/S R. 19 E. Douglas County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Boulders		0	4	
CG		4	9	
CG & Boulders (Hard Drilling)		9	52	
Gravel - Making Water		52	58	
Boulders & CG Hard Drilling		58	73	
Boulders & Clay Hard!		73	81	
Brown Sandy Clay		81	85	
CG Sand - Water		85	101	
Sand & Gravel - Water		101	107	
Gravel & Clay		107	109	
Dark Sandy Clay		109	110	

8. WELL CONSTRUCTION 110
 Diameter hole 3 inches Total depth 110 feet
 Casing record 5/8
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>3</u> inches	<u>1</u> feet	<u>110</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory Cut
 Size perforation 1 7/8 x 2"
 From 0' feet to 110 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 34 Feet below land surface 0
 Flow _____ G.P.M. 22
 Water temperature _____ ° F. Quality _____

Date started May 2, 19 77
 Date completed May 21, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jerome Bergstad
 Address 49 Riley Circle
 Nevada contractor's license number 122361
Nevada Pump and Drilling
 Nevada driller's license number #662
 Signed Jerome R. Bergstad
 Date May 21, 1977

BAILER TEST
 G.P.M. 22 Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours