DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 16753
Permit No.
Basin

1. OWNER Swift Builders ADDRESS 1031 Riverview-Gardnerville, Nev.
Lot #63 Fish Springs Estates

2. LOCATION NW ¼ ¼ Sec. 5 T. 12 N/S R. 21 E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable XX Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
Clay & Gravel		8	28	20
Clay		28	42	14
Clay to Gravel		42	75	33
Loose Gravel	WB	75	81	6
Clay		81	85	4
Sand & Gravel	WB	85	93	8
Clay		93	97	4

Date started Aug. 1, 19 77
Date completed Aug. 9, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down 30 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 97 feet
Casing record 8 5/8
Weight per foot Thickness .188

Diameter	From	To
8 inches	0 feet	97 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes XX No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No XX
Gravel packed from feet to feet

Perforations:
Type perforation Factory Cut
Size perforation 1/8 X 4
From 77 feet to 97 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 30 Feet below land surface
Flow G.P.M. 20
Water temperature Cool F. Quality Clay

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name James House
Address P.O. Box 351
Nevada contractor's license number ~~#1296A~~ #12236A
Nevada driller's license number 846
Signed James House
Date aug 9, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471