WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 16922
Permit No. 28722
Basin

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

1. OWNER W. H. Johnson ADDRESS November 5, 1976

2. LOCATION SW ¼ NW & NW¼ SW¼ Sec. 2 T. 32N N/S R. 34 E. Pershing County
PERMIT NO. 28722

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐ RVC

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 6 | 6 |
| Sand | | 6 | 20 | 14 |
| Sand & Brown Clay | | 20 | 60 | 40 |
| Sandy Clay | | 60 | 80 | 20 |
| Brown Sandy Clay | | 80 | 140 | 60 |
| Sandy Clay Reddish | | 140 | 160 | 20 |
| Sandy Grey Clay W/ Few Boulders | | 160 | 180 | 20 |
| Brown Sticky Clay | | 180 | 200 | 20 |
| Brown Sandy Clay | | 200 | 210 | 10 |
| Sticky Clay | | 210 | 220 | 10 |
| Brown Sticky Clay | | 220 | 270 | 50 |
| Sand | | 270 | 280 | 10 |
| Sand | | 280 | 290 | 10 |
| Clay | | 290 | 300 | 10 |
| Sand and Small Gravel | | 300 | 340 | 40 |
| Sand | | 340 | 580 | 240 |

Date started October 20, 19 76
Date completed October 31, 19 76

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 24 inches Total depth 580 feet
Casing record 580
Weight per foot 43# Thickness 1/4"

| Diameter | From | To |
|---|---|---|
| 12 inches | 0 feet | 580 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☒ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Louver
Size perforation 3/32" x 2"
From 180 feet to 580 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Armstrong Brothers
4710 Highway 40 West
Address Winnemucca, Nevada 89445

Nevada contractor's license number 5348

Nevada driller's license number 617-619-620

Signed Joe L. Armstrong

Date November 5, 1976

USE ADDITIONAL SHEETS IF NECESSARY

5471