DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 16980
Permit No.
Basin

1. OWNER LARRY TRIGUEIRO ADDRESS 2585 E. 9th St. Reno, Nevada

Silver Knolls Ranch Estates - Unit 3 - Lot 10

2. LOCATION N ¼ ¼ Sec. 25 T. 21N N/S R. 18 E. Washoe County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Loam		0'	7'	7'
Clay		7'	22'	15'
Clay & Sand		22'	40'	18'
Coarse brown & white sand (first water 50')		40'	60'	20'
Coarse brown sand		60'	63'	3'
Sticky Clay		63'	67'	4'
Coarse brown sand and gravel		67'	90'	23'

Date started October 1, 19 77
Date completed October 4, 19 77

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 12 feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 90 feet
Casing record 8"
Weight per foot Thickness .188

Diameter	From	To
8 inches	0 feet	90 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 1/16" X 2"
From 50 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60 Feet below land surface
Flow 30+ G.P.M.
Water temperature ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Russell C. Kabisch
Address 2270 E. Lake Blvd. Carson City, Nevada 89701

Nevada contractor's license number 14170

Nevada driller's license number 8671

Signed Russell C. Kabisch

Date October 5, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471