WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 17030
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Tom Neeser ADDRESS 1301 Cordone Suite #307 Reno, Nevada 89502

2. LOCATION ¼ ¼ Sec. 15 T. 19N N/S R. 18 E. Washoe County
PERMIT NO. Test Hole #3

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other TEST ☒

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay Mix med loose clay is sticky		0	21	21
Blue clay & rock 1/8 & ¼ med loose		21	120	99
Blue rock & some clay 1/8 & ¼ med loose		120	128	8
Blue & Black rock ¼ & ½ med loose		128	160	32

Date started 9-30-77, 19
Date completed 9-30-77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	45 GPM @	102' depth	
	52 GPM @	127' "	"

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 160 feet
Casing record
Weight per foot Thickness

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40' Feet below land surface
Flow G.P.M.
Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
Address P.O. Box 404; Sparks, NV 89431
Nevada contractor's license number 9767
Nevada driller's license number 817
Signed F. Padilla by W.L. McDonald
Frank Padilla by: W.L. McDonald
Date 4 October, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471