

Log No. 17036
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Greg Reddicks ADDRESS 100 Vassar Suite #209
Reno, Nevada 89502

2. LOCATION 1/4 NE 1/4 Sec. 25 T. 21N N/S R. 18 E Washoe County
 PERMIT NO. 11450 Vicksburg Road - SILVER KNOLLS - RND.

3. TYPE OF WORK				4. PROPOSED USE				5. TYPE WELL					
New Well	<input checked="" type="checkbox"/>	Recondition	<input type="checkbox"/>	Domestic	<input checked="" type="checkbox"/>	Irrigation	<input type="checkbox"/>	Test	<input type="checkbox"/>	Cable	<input type="checkbox"/>	Rotary	<input checked="" type="checkbox"/>
Deepen	<input type="checkbox"/>	Other	<input type="checkbox"/>	Municipal	<input type="checkbox"/>	Industrial	<input type="checkbox"/>	Stock	<input type="checkbox"/>	Other	<input type="checkbox"/>	AIR	

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Red & brown sandy clay fine some gravel		0	20	20
Vari colored sand fine to coarse		20	22	2
Light brown sandy clay fine to coarse med		22	25	3
Light brown sandy clay fine to coarse more sand		25	35	10
Vari colored sand & gravel fine 3/4"		35	38	3
Light brown sandy caly fine 3/4" med Layered		38	42	4
Vari colored sand fine to med decomposed granite type sand		42	55	13
Brown sandy clay fine		55	65	10
Vari colored sand fine to coarse loyers of sand & clay		65	93	28
Brown clay med		93	108	15
Vari colored sand fine to med		108	114	6
Brown sandy caly fine to med		114	140	26
Brown sandy clay fine to med more sand then clay		140	160	20
Brown clay med fine sand				

Date started 9-14-77, 19_____
 Date completed 9-19-77, 19_____

7. WELL TEST DATA			
Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	8-12 GPM	@ 180'	depth

8. BAILER TEST			
G.P.M.	Draw down	feet	hours

8. WELL CONSTRUCTION			
Diameter hole	<u>6</u> inches	Total depth	<u>192</u> feet
Casing record	<u>0</u> x <u>192'</u>	<u>6</u> x <u>5/8"OD</u>	
Weight per foot	<u>12.89</u>	Thickness	<u>188</u>
Diameter	From	To	
<u>10</u> inches	<u>0</u> feet	<u>50</u> feet	
<u>8 1/2</u> inches	<u>50</u> feet	<u>192</u> feet	
Surface seal: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Type	<u>transit mix</u>	
Depth of seal	<u>50'</u>		feet
Gravel packed: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>			
Gravel packed from		feet to	feet
Perforations:			
Type perforation	<u>factory mill slot</u>		
Size perforation	<u>1/8" x 2 1/2"</u>		
From	<u>152</u> feet to	<u>192</u> feet	
From			feet

9. WATER LEVEL
 Static water level 120 Feet below land surface
 Flow _____ G.P.M.
 Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404; Sparks, NV 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 805
 Signed T. Betita by W.L. McDonald
 Tony Betita by: W.L. McDonald
 Date 23 September, 1977

