

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 17119  
 Permit No. \_\_\_\_\_  
 Basin. \_\_\_\_\_

1. OWNER STARLITE HOMES ADDRESS 1000 MONTE VISTA DRIVE  
RENO, NEVADA 89511

2. LOCATION APN = 45-573-14  
1/4 NE 1/4 Sec. 2 T. 17 N/S R. 19 E. WASHOE County  
 PERMIT NO. LOT 10 MT. MEADOWS SUBDIVISION GALAHN RAND

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVER BURDEN WITH LARGE BOULDERS		0	8	8
SAND & GRAVEL (TIGHT)		8	48	40
SAND & GRAVEL (LOOSE)		48	106	58
BROWN & SANDY: MUD WITH GRAVEL		106	125	19
WATER BEARING FRACTURES FOUND AT: 100' and 105'				

8. WELL CONSTRUCTION

Diameter hole 6/5/8 inches Total depth 125 feet  
 Casing record 129' of 6-5/8" OD  
 Weight per foot \_\_\_\_\_ Thickness 188

Diameter	From	To
_____ inches	_____ feet	_____ feet
<u>6 -5/8</u> inches	<u>0</u> feet	<u>129</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type CEMENT  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 125 feet

Perforations:  
 Type perforation FACTORY SAWED SLOTS  
 Size perforation 3/32" X 2-1/2 X 6 Around  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 96 feet to 116 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 10-19, 1977  
 Date completed 10-20, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 63 Feet below land surface  
 Flow 10 G.P.M.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC.  
 Address P.O. BOX 347 NEWCASTLE, CA 95658  
 Nevada contractor's license number 14043  
 Nevada driller's license number 471  
 Signed \_\_\_\_\_  
 Date 11-3-77

BAILER TEST

G.P.M.	Draw down	feet	hours