WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17278
Permit No.
Basin

1. OWNER John E. Creem ADDRESS Beaver St. New Washoe City

2. LOCATION ¼ ¼ Sec. 31 T. ~~16~~ 17 N/S R. 20 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black top soil		0	46	4
Orange ~~sand~~ D.g		4	32	28
gravel & water	36	32	40	8
Blue sand & water		40	73	33
2 ft Brown clay + Wal. 2+3"		73	89	16
Blue sand & water		89	108	19
Blue clay		108	109	1

Mild steel shoe
plug at the bottom 4 ft.

Date started 10-77, 19
Date completed 11-1-77, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 40 feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 = 50' 8 = 59 inches Total depth 109 feet
Casing record ~~16~~ 8 ⅝
Weight per foot 16.5 Thickness 188 wall

Diameter	From	To
8 inches	0 feet	109 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 3 X 3/32
From 89 feet to 109 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20 Feet below land surface
Flow G.P.M. 40
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Labrum Well Drilling
Address P.O. Box 543 Dayton, Nev.
Nevada contractor's license number 14020
Nevada driller's license number 717
Signed Warren W Labrum
Date 11-1-77

USE ADDITIONAL SHEETS IF NECESSARY

5471