WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 17357
Permit No.
Basin

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

1. OWNER Overland Builders Corp. ADDRESS Lemmon Valley

Well Location: Highest House on Deodar St.

2. LOCATION NW ¼ NW ¼ Sec. 15 T. 21 N N/S R. 19 E. Washoe County

PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0' | 8' | 8' |
| Sandy Clay | | 8' | 17' | 9' |
| Clay/Sand Streaks | | 17' | 85' | 68' |
| Sand + Grav. | * | 85' | 90' | 5' |
| Sandy Clay | | 90' | 112' | 22' |
| Coarse Sand | ** | 112' | 119' | 7' |
| Sandy Clay | | 119' | 137' | 18' |
| Coarse Sand/Grav. | ** | 137' | 141' | 4' |
| Clay with sand | | 141' | 144' | 3' |
| ~~Co~~ Sand | * | 144' | 149' | 5' |
| Sandy Clay | | 149' | 153' | 4' |

Date started Nov. 28, 19 77
Date completed ~~Nov.~~ Dec. 6, 19 77

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 15 Draw down 20 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 153 feet
Casing record
Weight per foot Thickness 188

| Diameter | From | To |
|---|---|---|
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Ready Mix
Depth of seal 70 feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation Mill
Size perforation 3/32
From 110' feet to 150' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static-water-level 85' Feet below land surface
Flow G.P.M. 15
Water temperature Cool ° F. Quality Clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim U. Enloe
Address P.O. Box 235, Janesville Ca. 96114
Nevada contractor's license number 4739 A
Nevada driller's license number 794
Signed Jim U. Enloe
Date Dec. 12, 1977

USE ADDITIONAL SHEETS IF NECESSARY

5471