WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 17418
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Bill Allen ADDRESS East Washoe City
Lot 3 Block 'K' Rabbit St

2. LOCATION SE ¼ NW ¼ Sec. 31 T. 17 N/S R. 20 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	1	1
Brown Sandy Clay		1	9	8
D. G. Sand		9	31	22
Fine Sand + water	31	31	60	29
Medium to Course Sand w/water		60	76	16
Gray-green Sticky Clay		76	82	6

Date started January 3, 1978
Date completed January 3, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 inches Total depth 82 feet
Casing record 6 5/8
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	82 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 82 feet

Perforations:
Type perforation FACTORY
Size perforation "16"
From 56 feet to 76 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 37 Feet below land surface
Flow 25 G.P.M.
Water temperature ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Pura Drilling & Well Service
Address P.O. Box 223 Stewart, Nv
Nevada contractor's license number 14327
Nevada driller's license number 932
Signed Milbert Eudy
Date Jan 9, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471