WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17481
Permit No.
Basin

5920 Grass V. Road
APN 077-360-16

1. OWNER David Lisser ADDRESS P.O. Box 2776 Sparks 89431

2. LOCATION NW ¼ SW ¼ Sec. 28 T. 23 N/S R. 21 E. Washoe County
PERMIT NO.

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red Clay & Broken Rock		1	97	
Broken Rock	X	95	135	
Deepened by log # 32451				

Date started Jan 2, 19 78
Date completed Jan 2, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 135 feet
Casing record 1 to 135
Weight per foot ..... Thickness .156

Diameter	From	To
6 inches	1 feet	135 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 135 feet to 50' feet

Perforations:
Type perforation factory
Size perforation 1/16
From 115 feet to 135 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 90 Feet below land surface
Flow ..... G.P.M. 15
Water temperature Cool °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Kawasaki Pump & Well Service
Address Box 536 Gardnerville Nev.
Nevada contractor's license number 15714
Nevada driller's license number 533
Signed Robert A. Kawasaki
Date Jan 2, 1978

USE ADDITIONAL SHEETS IF NECESSARY

5471