

Log No. 17570
Permit No. _____
Basin. 68

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER George Hatjakes ADDRESS 3278 Saltern Way
Sparks, Nevada 89431

2. LOCATION 1/4 SE 1/4 Sec. 35 T. 18N N/S R. 19 E. Washoe County
PERMIT NO. S.E. Wintergreen and Tannerwood Mt. Rose, Galena

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown cobblestones coarse rock to 1/2" fair		0	10	10
Black, white & gray boulders coming out in chips fair		10	20	10
Bray & white mica granite boulders rock to 1/2" slow		20	25	5
Gray & some red boulders & rock coarse rock to 1/2" fair		25	33	8
Gray 20% red rock chips of gray to 1/2" red 1/16" fair		33	40	7
Loose gravels & brown sands		40	50	10
Granite boulders gray in color		50	75	25
Granite boulders loose sands brown & gray		75	100	25
Gray & red & brown med to fine sands		100	125	25
First water gray & brown loose sands		125	150	25
Have water gray brown sands drilled fast		150	177	27

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 177 feet
Casing record 0 - 177' x 6.5/8 O.D.
Weight per foot 12.89 Thickness 18.8

Diameter	From	To
10 inches	0 feet	50 feet
8 1/2 inches	50 feet	177 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes No Type transit mix
Depth of seal 50' feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet

Perforations:
Type perforation factory mill slot
Size perforation 1/8 x 2 1/2"
From 15.7 feet to 177 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Date started 11-3-77, 19_____
Date completed 11-7-77, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	23.08	GPM 140'	depth
	35.	GPM @ 154'	depth

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 110' Feet below land surface
Flow _____ G.P.M.
Water temperature cold F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
Address P.O. Box 404; Sparks, NV 89431
Nevada contractor's license number 9767
Nevada driller's license number 923
Signed E. Mondragon by W.L. McDonald
Ed Mondragon by: W.L. McDonald
Date 10 November, 1977