

OFFICE USE ONLY
 Log No. 12571
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Ray Celch ADDRESS 2815 Everett Drive
Reno, Nevada 89503

2. LOCATION 1/4 SE 1/4 Sec. 11 T. 18N N/S R. 19 E Washoe County
 PERMIT NO. Lot #41 4200 Slide Mt. Drive Southwest Estates

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Top soil		0	5	5
Brown sand broken rock				
1/2 - 1"		5	25	20
Brown broken rock 1/2 - 1"		25	50	25
Purple broken rock		50	75	25
Purple broken rock looks like volcanic rock		75	100	25
Purple & red ; fine Red & gray gravel & broken rock 1/2 - 3/4"		100	125	25
little water		125	150	25
Red & gray gravels 1/2 - 1/2" picking up more water		150	170	20
Red & gray gravels 1/2 - 1/2" WATER		170	185	15

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 185' feet
 Casing record 0 - 185' x 6 5/8 O.D.
 Weight per foot 12.89 Thickness .188

Diameter	From	To
<u>10</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8 1/2</u> inches	<u>50</u> feet	<u>185</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type transit mix
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation factory mill slot
 Size perforation 1/8 x 2 1/2"

From	To
<u>165</u> feet	<u>185</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Date started 11-28-77, 19_____
 Date completed 11-28-77, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	14 GPM @	150' depth	
	27 GPM @	175' depth	

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 1.25' Feet below land surface
 Flow _____ G.P.M.
 Water temperature cold °F. Quality not tested

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404; Sparks, NV 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 923
 Signed Ed Mondragon
 Ed Mondragon
 Date 7 December, 1977