

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Paul Hemming ADDRESS Minden Nev
 2. LOCATION S.E. 1/4 S.E. 1/4 Sec. 35 T. 14 N. N/S R. 20 E. Douglas County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand & Clay</u>		<u>0</u>	<u>25</u>	<u>25</u>
<u>Clay</u>		<u>25</u>	<u>160</u>	<u>85</u>
<u>Gravel</u>	<u>W/B</u>	<u>160</u>	<u>170</u>	<u>10</u>
<u>Clay</u>		<u>170</u>	<u>175</u>	<u>5</u>
<u>Sand</u>	<u>W/B</u>	<u>175</u>	<u>185</u>	<u>10</u>
<u>Blue Clay</u>		<u>185</u>	<u>191</u>	<u>6</u>

8. WELL CONSTRUCTION
 Diameter hole 8 5/8 inches Total depth 191 feet
 Casing record _____
 Weight per foot _____ Thickness 188

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory
 Size perforation 1/16
 From 15.1 feet to 191 feet
 From _____ feet to _____ feet

Date started 1-25, 1928
 Date completed 2-4, 1928

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 1.50 Feet below land surface
 Flow _____ G.P.M. 12
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled by JIM HOUSE & SONS report is true to the best of my knowledge. **DRILLING**
 P.O. Box 2192
 Name Carson City, NV 89701
882-0338
 Address _____
 Nevada contractor's license number 12554
 Nevada driller's license number 651
 Signed Steve House
 Date 2-5-28

BAILER TEST
 G.P.M. 12 Draw down 30 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours