

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Robert Games ADDRESS 2450 Ferretto Lane
Reno, Nevada 89511
 2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 2 T. 18N N/S R. 19 E. Washoe County
 PERMIT NO. 2450 Ferretto Lane Reno

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown topsoil fine		0	1	1
Brown boulders and sands med. to coarse		1	15	14
Red, brown, yellow and white broken rock and sands med to coarse		15	45	30
Brown, black and red broken rock & sand - clay med to fine first water 65-75		45	75	30
Brown, black red yellow & white clays & broken rock $\frac{3}{4}$ " to $\frac{1}{2}$ " some fines		75	125	50
Brown & white boulders & clay $\frac{1}{2}$ - $\frac{1}{4}$ " some sands & fines		125	150	25
Brown, black w/ white spots in it - rock, clay		150	165	15
Black sand fine		165	190	25

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 190' feet
 Casing record 0 - 190' x 6 5/8 O.D.
 Weight per foot 12.89 Thickness .188

Diameter	From	To
<u>1.0</u> inches	<u>0</u> feet	<u>5.0</u> feet
<u>8 1/2</u> inches	<u>5.0</u> feet	<u>19.0</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type transit mix
 Depth of seal 5.0' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory mill slot
 Size perforation 1/8 x 2 1/2"
 From 11.0 feet to 19.0 feet
 From _____ feet to _____ feet

Date started 2-3-78, 19____
 Date completed 2-3-78, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	10-12 GPM @	17.5' depth	

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 1.7' Feet below land surface
 Flow _____ G.P.M.
 Water temperature c.o.l.d. °F. Quality not tested

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W.L. McDonald & Co., Inc.
 Address P.O. Box 404; Sparks, NV 89431
 Nevada contractor's license number 9767
 Nevada driller's license number 805
 Signed Tony Betita by W.L. McDonald
 Tony Betita by: W.L. McDonald
 Date _____
6 February, 1978