WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 17795
Permit No.
Basin

1. OWNER Nolan Magklin ADDRESS Beach Road, Silver Springs
#209 Mountain View #2

2. LOCATION NE ¼ NW ¼ Sec. 5 T. 17 N/S R. 25 E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	10	10
Clay		10	21	11
Coarse Sand		21	30	9
Clay		30	35	5
Coarse Sand		35	50	15
Clay with Fine Sand Streaks		50	80	30
Brown Sand		80	90	10
Gravel & Coarse Sand	X	90	110	20
Gravel & Small Rock	X	110	124	14

Date started March 24, 19 78
Date completed March 28, 19 78

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 22 Draw down 5 feet 1 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 5/8 inches Total depth 124 feet
Casing record
Weight per foot Thickness .156

Diameter		From		To	
6	inches	0	feet	124	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 124 feet

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 rows
From 94 feet to 124 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 Feet below land surface 40
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Well Drilling
Address 150 North Byler Ln
Nevada contractor's license number 6540
Nevada driller's license number 634
Signed Larry Ogden
Date 3/29/78

USE ADDITIONAL SHEETS IF NECESSARY

5471