

Log No. 17820
 Permit No. _____
 Basin _____

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Robert Caputo ADDRESS Marion Valley

2. LOCATION $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 11 T. 11 N/S R. 25 E. Lyon County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand & Gravel</u>		<u>0</u>	<u>30</u>	
<u>Gravelly Clay</u>		<u>35</u>	<u>55</u>	
<u>Yellow Sand</u>		<u>55</u>	<u>100</u>	
<u>Sandy Clay</u>	<u>x</u>	<u>100</u>	<u>160</u>	
<u>Clay</u>	<u>x</u>	<u>160</u>	<u>170</u>	

8. WELL CONSTRUCTION
 Diameter hole 10" inches Total depth 170' feet
 Casing record 6" CD
 Weight per foot 10.9 lbs Thickness 1.69"

Diameter	From	To
<u>6" Blank</u> inches	<u>0</u>	<u>130</u> feet
<u>6" P.T.F.</u> inches	<u>130</u>	<u>170</u> feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet
_____ inches	_____	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Vert. Slot
 Size perforation 1/8" x 2" 6 Rows
 From 130 feet to 170 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 49' Feet below land surface 49'
 Flow _____ G.P.M.
 Water temperature 70 ° F. Quality C

Date started 3-14, 1978
 Date completed 3-15, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles E. Roberts
 Address 1718 Verbenen Sparks Ave

Nevada contractor's license number _____
 Nevada driller's license number 957

BAILER TEST
 G.P.M. 15 Draw down 2 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Charles E. Roberts
 Date 3-15-78