WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 17944
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER COULTIN LEWIS ADDRESS 2520 E. NINTH STREET RENO, NEVADA 89512

2. LOCATION ¼ ¼ Sec. 23 T. 21N N/S R. 19E E. ~~Wd~~ Washoe County
~~PERMIT NO~~ Lot 10 Block 11 Heppner Sub #4

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top soil		0	4	4
Clay ad Sand		4	86	82
Decomposed granite with gravel streaks	XX	86	175	99
Decomposed granite with clear quartz streaks	XX	175	194	19

Date started 4-11-, 19 78.
Date completed 4-12-78., 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 194 feet
Casing record 194 ft. 6-5/8" OD
Weight per foot Thickness .188

Diameter	From	To
inches	feet	feet
6-5/8 inches	0 feet	194 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 55 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 55 feet to 194 feet

Perforations:
Type perforation Factory Sawed Slots
Size perforation 3/32" X 2½ X 6 Around
From feet to feet
From 148 feet to 198 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 120 Feet below land surface
Flow 158 G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC.
Address P.O. BOX 347 NEWCASTLE, CALIF. 95658
Nevada contractor's license number 14043
Nevada driller's license number 471
Signed Wayne Redman
Date 4-20-78

USE ADDITIONAL SHEETS IF NECESSARY

5471