

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER MADOLE Coush ADDRESS 16205 Sander Way  
50 BEAR ST., LOT 20 BLOCK I  
NEW WASHOE SUBDIVISION #33 RENO, NEV 89511  
 2. LOCATION  $\frac{1}{4}$   $\frac{1}{4}$  Sec.  $\frac{36}{16}$  T.  $17$  N/S R. 20 E. Washoe County  
 PERMIT NO. Lot #50 Brant

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Clay</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>SAND</u>		<u>10</u>	<u>100</u>	<u>90</u>
<u>Firstwater 20'</u>				

8. 12" = 50' WELL CONSTRUCTION  
 Diameter hole 50 = 8" Total depth 100 feet  
 Casing record 8 5/8"  
 Weight per foot 16.9 Thickness 1.88  

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>100</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Factory  
 Size perforation 3/4 3/32  
 From 48 feet to 48 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3-29-78, 19\_\_\_\_  
 Date completed 4-7-78, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 30 Draw down 20 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 10 Feet below land surface  
 Flow NO G.P.M.  
 Water temperature cold Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W. M. Blain  
 Address Box 353 Dayton NV  
89403  
 Nevada contractor's license number 10950  
 Nevada driller's license number 929  
 Signed Clayton Faust  
 Date 5/12/78