WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 18206
Permit No.
Basin

1. OWNER JERRY ANASTASSATOS ADDRESS 10175 CALLE MARIA SILVER CLIFF

2. LOCATION ¼ ¼ Sec. 25 T. 21 N/S R. 18 E. WASHOE County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface Soil w/Clay		0	1	1
Lt Clay w/DG		1	7	6
Decomposed Granite		7	23	16
Clay, Various Colors		23	59	36
D.G Sand Coarse		59	68	7
D G w/Clay Stringers		68	99	31
Clay		99	104	5
Clay w/DG Stringers		104	108	4
DG w/Small Clay Stringers		108	122 TD	14

Date started 3 Aug, 1977
Date completed 8 Aug, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	Not Tested		

BAILER TEST
G.P.M. Not Draw down feet hours
G.P.M. Tested Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 122 feet
Casing record 6
Weight per foot Thickness

Diameter	From	To
6" inches	41 feet	122 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 51 feet to 122 feet

Perforations:
Type perforation Slot
Size perforation 1/8 x 3
From 82 feet to 122 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump & Well Co.
Address P.O. Box 99 Steamboat Springs
Nevada contractor's license number 1189
Nevada driller's license number 765
Signed [illegible]
Date 8 Aug