

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER June Hanson ADDRESS 17950 South Virginia
Corner of 395 & Andrews Lane
2. LOCATION 1/4 SW 1/4 Sec 4 T. 10 N/S R. 20 E. Washoe County
PERMIT NO. T. 17 N.

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Clay		3	7	4
Red Sand Gravel	✓	7	9	2
Clay to Gravel		9	36	27
Hard Redd Vol		36	42	6
Gravel clay		42	53	11
Broken Redd	✓	53	67	14

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 67 feet
Casing record.....
Weight per foot..... Thickness 188
Diameter From To
6 7/8 inches 0 feet 67 feet
..... inches feet feet
Surface seal: Yes No Type Comment
Depth of seal 60 feet
Gravel packed: Yes No
Gravel packed from..... feet to..... feet
Perforations:
Type perforation Sector
Size perforation 1/4 x 3
From 57 feet to 67 feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet
From..... feet to..... feet

9. WATER LEVEL
Static water level 8 Feet below land surface
Flow..... G.P.M.
Water temperature cold F. Quality.....

Date started May 19, 1978
Date completed May 30, 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>no test</u>			

BAILER TEST
G.P.M. Draw down.....feethours
G.P.M. Draw down.....feethours
G.P.M. Draw down.....feethours

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Steven Pump & Supply
Address P.O. Box 99, Steamboat, Nev.
Nevada contractor's license number 11139
Nevada driller's license number 675
Signed J. G. M. Steven
Date May 30, 1978