WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

#5

OFFICE USE ONLY
Log No. 18245
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Security Housing ADDRESS Reno NV

2. LOCATION ¼ SE ¼ Sec. 10 T. 20 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Dg Granite		15	70	55
Broken Granite		70	90	20
Broke Granite Soft	water	90	93	3
Granite hard		93	100	7
Broken Granite		100	120	120
Some water				

Date started 3-27 19 75
Date completed 3-28 19 75

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
		0	53 0 53

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 120 feet
Casing record 6"
Weight per foot ..... Thickness 156

Diameter		From		To	
6	inches	0	feet	120	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation Torch
Size perforation
From 80 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... Feet below land surface
Flow ..... G.P.M.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Well Shop
Address Sparks NV
Nevada contractor's license number 14508
Nevada driller's license number 935
Signed Larry Martin
Date 3-28-75

USE ADDITIONAL SHEETS IF NECESSARY

5471

OFFICE
STATE ENGINEER

1978 JUN 6 AM 9 37