

DUPLICATE

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER ERGS, Inc. ADDRESS P.O. Box 11525, Reno, Nev. 89510

2. LOCATION NW 1/4 SE 1/4 Sec 26 T. 18 N/S R. 24 E. Lyon County
 PERMIT NO. 28797

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand and Small Gravel		0	28	28
Clay Boulders mixed		28	138	110
Blue Shale		138	158	20
Sandstone		158	188	30
Black Shale		188	198	10
Hard Stone (sand)		198	208	10
Schale		208	298	90
Black Schale		298	378	80
Blue Schale		378	418	40
Sandy Schale Gray		418	448	30
Blue Schale		448	468	20
Gray Sandy Schale		468	518	50

8. WELL CONSTRUCTION
 Diameter hole 24 inches Total depth 518 feet
 Casing record 518'
 Weight per foot 39 lbs Thickness 1"

Diameter	From	To
14 inches	0 feet	518 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

 Surface seal: Yes No Type
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 518 feet
 Perforations:
 Type perforation Louver
 Size perforation 3/23" x 2"
 From 144 feet to 518 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

9. WATER LEVEL
 Static water level Feet below land surface
 Flow G.P.M.
 Water temperature ° F. Quality

Date started February 18, 1977
 Date completed February 22, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	150 at	400'	

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Armstrong Brothers
 4710 Highway 40 W
 Address Winnemucca, Nevada 89445
 Nevada contractor's license number 5348
 Nevada driller's license number 617-619-620
 Armstrong Bros.
 Signed By: Joe L. Armstrong
 Date March 8, 1977

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours