

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Bill Gondolfa ADDRESS Austin NV  
2. LOCATION S 1/4 7 W 1/4 Sec 36 T 20 N S R 40 E Tander County  
PERMIT NO. ....

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other   
4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock   
5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	30	30
Clay & sand		30	70	40
Sand	Water	70	77	7
Sand & gravel	Water	77	94	17
Clay & sand		94	140	46
Shale		140	155	15
Sand & shale		155	250	95
Bentonite		250	285	35
Brown Rock		285	305	20

Plugged back to 200' and set casing

8. WELL CONSTRUCTION  
Diameter hole 10 inches Total depth 305 feet  
Casing record 6" 200'  
Weight per foot..... Thickness 10 ga.  
Diameter From To  
6 inches 0 feet 200 feet  
..... inches ..... feet ..... feet  
Surface seal: Yes  No  Type Cement  
Depth of seal..... 50' feet  
Gravel packed: Yes  No   
Gravel packed from..... 50' feet to 200' feet  
Perforations:  
Type perforation..... touch  
Size perforation..... 3/16 X 12 1/4  
From..... 68 feet to..... 138 feet  
From..... feet to..... feet  
From..... feet to..... feet  
From..... feet to..... feet  
From..... feet to..... feet

Date started..... 5/19 1978  
Date completed..... 5/30 1978

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
G.P.M. .... Draw down..... feet ..... hours  
G.P.M. .... Draw down..... feet ..... hours  
G.P.M. .... Draw down..... feet ..... hours

9. WATER LEVEL  
Static water level..... 0 Feet below land surface  
Flow..... Yes G.P.M.  
Water temperature..... ° F. Quality..... good

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name..... Susita Well Drilling  
Address..... Sparks NV  
Nevada contractor's license number..... 14508  
Nevada driller's license number..... 989  
Signed..... Floyd Susita  
Date..... 5/30/78